

Castle Pines Metropolitan District 2011 Drinking Water Consumer Confidence Report For Calendar Year 2010

Public Water System ID # CO0118005

Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.

We are pleased to present to you this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water.

General Information About Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides** that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff,

and septic systems.

- **Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems (especially for pregnant women and young children). It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. If you are concerned about lead in your water, you may wish to have your water tested. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Our Water Source(s)

Source	Water Type
Well A10	Ground Water
Well De10R	Ground Water
Well Lda10R	Ground Water
Well A8	Ground Water
Well De8	Ground Water
Well A 4R	Ground Water
Well A12	Ground Water
Well De2	Ground Water
Well Lda12	Ground Water

The Colorado Department of Public Health and Environment has provided us with a Source Water Assessment Report for our water supply. You may obtain a copy of the report by visiting www.cdphe.state.co.us/wq/sw/swaphom.html or by contacting John Ferguson at 303-688-8330.

Potential sources of contamination in our source water area come from: Aboveground, Underground and Leaking Storage Tank Sites, Urban Recreational Grasses, Fallow,

Deciduous Forest, Evergreen Forest, Septic Systems, and Road miles.

The Source Water Assessment Report provides a screening-level evaluation of potential contamination that **could** occur. It does not mean that the contamination **has or will** occur. We can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan.

Please contact John Ferguson at 303-688-8330 to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Consumer Confidence Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.

Detected Contaminants

Castle Pines Metropolitan District routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2010 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. The “Range” column in the table(s) below will show a single value for those contaminants that were sampled only once. Violations, if any, are reported in the next section of this report.

Note: Only detected contaminants appear in this report. If no tables appear in this section, that means that Castle Pines Metropolitan District did not detect any contaminants in the last round of monitoring.

<u>Terms and Abbreviations</u>		
<u>Term</u>	<u>Abbreviation</u>	<u>Definition</u>
Maximum Contaminant Level Goal	MCLG	The 'Goal' is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Contaminant Level	MCL	The 'Maximum Allowed' is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Below Detection Level	BDL	Sample results were below minimum detectable amounts
Treatment Technique	TT	A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
Action Level	AL	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Maximum Residual Disinfectant Level Goal	MRDLG	The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum Residual Disinfectant Level	MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Average of Individual Samples	No Abbreviation	The typical value. Mathematically it is the sum of values divided by the number of samples.
Range of Individual Samples	No Abbreviation	The lowest value to the highest value.
Number of Samples	No Abbreviation	The number or count of values.
Gross Alpha, Including RA, Excluding RN & U	No Abbreviation	This is the gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222 and uranium.

Microscopic Particulate Analysis	MPA	An analysis of surface water organisms and indicators in water. This analysis can be used to determine performance of a surface water treatment plant or to determine the existence of surface water influence on a ground water well.
Variance and Exemptions	V/E	Department permission not to meet an MCL or a treatment technique under certain conditions.
Parts per million = Milligrams per liter	ppm = mg/L	One part per million corresponds to one minute in two years or a single penny in \$10,000.
Parts per billion = Micrograms per liter	ppb = ug/L	One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
Parts per trillion = Nanograms per liter	ppt = nanograms/L	One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
Parts per quadrillion = Picograms per liter	ppq = picograms/L	One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
Picocuries per liter	pCi/L	Picocuries per liter is a measure of the radioactivity in water.
Nephelometric Turbidity Unit	NTU	Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
Not Applicable	N/A	Not Applicable
Violation	No Abbreviation	A failure to meet a Colorado Primary Drinking Water Regulation.
Formal Enforcement Action	No Abbreviation	An escalated action taken by the State (due to the number and/or severity of violations) to bring a non-compliant water system back into compliance by a certain time, with an enforceable consequence if the schedule is not met.

Lead and Copper Sampled in the Distribution System									
Analyte Name	Monitoring Period	90th Percentile	Number of Samples	Unit of Measure	Action Level	Sample Sites Above Action Level	AL or TT Violation?	Typical Sources	Potential Health Effects from Long-Term Exposure Above the Action Level (unless specified as short-term)
COPPER	01/01/2008 to 12/31/2010	0.14	10	ppm	1.3	0	No	Corrosion of household plumbing systems; Erosion of natural deposits.	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
LEAD	01/01/2008 to 12/31/2010	2	10	ppb	15	0	No	Corrosion of household plumbing systems; Erosion of natural deposits.	Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Disinfection By Products (TTHMs, HAA5, and Chlorite) Sampled in the Distribution System										
Analyte Name	Year	Average of Individual Samples	Range of Individual Samples (Lowest - Highest)	Number of Samples	Unit of Measure	MCL	MCLG	MCL Violation?	Typical Sources	Potential Health Effects from Long-Term Exposure Above the MCL (unless specified as short-term)
TOTAL HALOACETIC ACIDS (HAA5)	2009	6.105	0 - 12.21	2	ppb	60	N/A	No	By-product of drinking water disinfection.	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.
TTHM	2009	13.56	4.92 - 22.2	2	ppb	80	N/A	No	Byproduct of drinking water disinfection.	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Regulated Contaminants Sampled at the Entry Point to the Distribution System										
Analyte Name	Year	Average of Individual Samples	Range of Individual Samples (Lowest - Highest)	Number of Samples	Unit of Measure	MCL	MCLG	MCL Violation?	Typical Sources	Potential Health Effects from Long-Term Exposure Above the MCL (unless specified as short-term)
BARIUM	2010	0.129	0.088 - 0.17	2	ppm	2	2	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
FLUORIDE	2010	0.89	0.78 - 1	2	ppm	4	4	No	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.
NITRATE	2010	0.048	0.043 - 0.052	2	ppm	10	10	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
NITRATE-NITRITE	2010	0.048	0.043 - 0.052	2	ppm	10	10	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.	Infants below the age of six months who drink water containing nitrate-nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

Radionuclides Sampled at the Entry Point to the Distribution System

Analyte Name	Year	Average of Individual Samples	Range of Individual Samples (Lowest - Highest)	Number of Samples	Unit of Measure	MCL	MCLG	MCL Violation?	Typical Sources	Potential Health Effects from Long-Term Exposure Above the MCL (unless specified as short-term)
COMBINED RADIUM (-226 & -228)	2010	2.5	2.4 - 2.6	2	pCi/L	5	0	No	Erosion of natural deposits.	Some people who drink water containing radium -226 or -228 in excess of the MCL over many years may have an increased risk of getting cancer.
GROSS ALPHA, EXCLUDING RADON & URANIUM	2010	2.65	1.9 - 3.4	2	pCi/L	15	0	No	Erosion of natural deposits.	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
GROSS BETA PARTICLE ACTIVITY*	2010	2.2	2.2	1	pCi/L*	50	0	No	Decay of natural and man-made deposits.	Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta particle and photon radioactivity in excess of the MCL over many years may have an increased risk of getting cancer.
RADON	2007	420	420	1	pCi/L	N/A	N/A	No	Naturally present in the environment.	See note below.

Radon is a radioactive gas that you cannot see, taste, or smell. It is found in the soil throughout the United States. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can reach high levels in all types of homes. Radon can also be released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through the soil, radon entering the home through tap water will be, in most cases, a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air that contains radon can lead to lung cancer. Drinking water that contains radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. Fix your home if the level of radon in your air is four (4) picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that are relatively inexpensive. For additional information, call the state radon program at 303

*The MCL for Gross Beta Particle Activity is 4 mrem/year. Since there is no simple conversion between mrem/year and pCi/L EPA considers 50 pCi/L to be the level of concern for Gross Beta Particle Activity.

Secondary Contaminants(SC)/ Other Monitoring(OM)	Year	Highest Value	Range	Unit	Secondary Standards/ MCL
SODIUM (SC)	2010	14.6	16	ppm	10000
TDS (SC)	2010	131	131	ppm	500
ANTIMONY (OM)	2009	BDL		ppm	.006
ARSENIC (OM)	2009	BDL		ppm	.010
BERYLLIUM (OM)	2009	BDL		ppm	.004
CADMIUM (OM)	2009	BDL		ppm	.005
CHROMIUM (OM)	2009	BDL		ppm	0.1
CYANIDE (OM)	2009	BDL		ppm	0.2
ENDOTHALL (OM)	2009	BDL		µg/L	100
MERCURY (OM)	2009	BDL		ppm	0.002
NICKEL (OM)	2009	BDL		ppm	None
SELENIUM (OM)	2009	BDL		ppm	0.05
THALLIUM (OM)	2009	BDL		ppm	0.002
RADON (OM)	2009	430	120-430	pCi/L	None

Secondary Contaminants (SC) standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply. **Other Monitoring (OM)** standards are usually enforceable guidelines for contaminants, which were either voluntarily tested and met or fell within the acceptable range of EPA Standards, or they were required by the State and were found to have no detectible contaminants.



Violations

Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2010			